



3301 NW 55th Street, Ft. Lauderdale, FL 33309
Tel: (888) 547-0477

Certificate of Asbestos Analysis

Prepared for: Your Company Name

Phone: 333-272-4311

Email: info@yourcompany.com

Test Address: Sally Mitchell
123 Main Street
Elkart, IN 46517

Laboratory COC #: 52245678

Date Collected: February 03, 2019

Receive Date: February 04, 2019

Analysis Date: February 04, 2019

Report Date: February 04, 2019

Asbestos Results:

Sample #1: BASEMENT CEILING TILE

NO ASBESTOS CONTAINING MATERIAL DETECTED

80% Cellulose
18% Minerals
2% Fiberglass

Sample #2: BASEMENT FLOORING TILE

ASBESTOS CONTAINING MATERIAL DETECTED

***2% Chrysotile Asbestos**
97% Minerals
1% Cellulose

A handwritten signature in black ink, appearing to read 'John D. Shane'.

John D. Shane Ph.D., QA Manager

This report shall not be reproduced, except in full, without written permission from InspectorLab. This report contains data that were produced under NVLAP #102053-0. Samples analyzed using EPA/600R-93/116 for bulk building materials and EPA/600/M4/82-020 for insulation materials.

Any action taken on the basis of this report is the full responsibility of the client for which this report was written.

Furthermore, InspectorLab's liability is limited to the cost of the analysis. Limit of Quantitation (LOQ) is 1%. "Trace", if listed, indicates the presence of asbestos below the LOQ. "ND" = None Detected.

*EPA requirements for reporting and analyzing asbestos are: Asbestos Containing (AC) = equal to or greater than 1%; None Asbestos Containing (NAD) is <1% even though the sample may contain a trace amount of Asbestos. If the PLM method is $\geq 1\%$ an point count may be performed (but is not required) to determine more precisely the amount of asbestos present in the samples(s). Visit www.epa.gov/iaq/asbestos.html for more information.

For more information please contact InspectorLab at 888-854-0477